



File Hills Qu'Appelle Tribal Council

Health Services

Treaty Four Territory

Reserve #77

Box 300

FORT QU'APPELLE, SK S0G 1S0

June 3, 2025

Chief Fabian Ironeagle & Council

Box 79 Paskwa

Pasqua First Nations, SK

S0G 5M0

ENVH-385-2

Wood Mountain

Dear Chief, Peigan

Re: Precautionary Boil Water Advisory for Subdivision 2 & 3

Little Black Bear

Star Blanket

This advisory is being issued due to water main breaks and repairs in subdivisions two and three.

We are recommending a Precautionary Boil Water (PBWA) until such time as the leaks are repaired and:

- A free chlorine level of at least 0.2 milligrams/Litre (mg/L).
- One negative bacterial samples.

Muskrat

Please find attached a poster which can be used to advise community members. If you have any questions or concerns, please contact me at 306-331-7930(cell).

Standing Buffalo

Sincerely,

Vaughn Williams, BAsC., CPHI(C)

Nekane

Environmental Public Health Officer

Deepeekisis

cc. Thomas Missen, Water Treatment Plant Operator, Pasqua First Nation
Kyle Chicoose, Health Director, Pasqua First Nation
Deon Hassler/Greg Bank, Circuit Rider Trainers, File Hills Qu'Appelle Tribal Council
Caroleen Stevens, Housing and Infrastructure, Pasqua First Nation
Dr. Kahn, Medical Health Officer, ISC-FNIHB
EHPH, ISC-FNIHB

Okanese

Pasqua

Piapot

Pasqua First Nation

Precautionary Boil Water Advisory

June 3, 2025

This notice is to advise you that due to Water line breaks and repairs, which can cause a loss in pressure.

During the repairs it is necessary to shut off the water, bottled water will be provided by Pasqua First Nation until the water is turned back on at which time:

- We are recommending a, Precautionary Boil Water (PBWA) until:
 1. A free chlorine level of at least 0.2 milligrams/Litre (mg/L).
 2. One negative bacterial sample.

You are advised to boil water that is to be used for **drinking, cooking or brushing your teeth**, for 3 minutes before it is used.

You will be notified once testing is completed to ensure that the water is safe to drink.

If you have any questions or concerns, please contact your Water Treatment Plant Operator or Vaughn Williams at 306-331-7930.

Vaughn Williams, BAsC., CPHI(C)
Environmental Public Health Officer

Issued June 3, 2025